

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1080552

Product: Safety power supply

Type: UNZ-10T-X06, UNZ-10T-X012, UNZ-10T-X024, UNZR-10T-X024

Rating: Uprim.=230 V AC, 50 Hz, Usek.=AC/DC 6, 12, 24 V, DC 1,2-24 V

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 801481-01/01 of: 13.05.2008

A sample of the product was found to be in conformity with:

ČSN EN 55022:07 ed.2,
ČSN EN 61000-6-1:07 ed.2,
ČSN EN 61558-1:06 ed. 2+1:06,
ČSN EN 61558-2-5:99+A11:05

The validity of the certificate is limited to: 30.6.2011

10.6.2008

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



801481-01