

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1090519

**Product:** Low-voltage surge protective devices

**Type:** SVC-255-N-S, SVC-275-1, SVC-275-1-S

**Rating:** Uc: AC 275 V, Up: ≤ 1,3 kV, In: 30 kA (SVC-255-N-S),  
Uc: AC 275 V, Up: ≤ 1,35 kV, In: 20 kA (SVC-275-1, SVC-275-1-S)

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 902126-01/01 of: 27.05.2009

**A sample of the product was found to be in conformity with:**

ČSN EN 61643-11:2003+A11:2007

cl.6.1.1,6.1.2,7.2.1,7.2.2,6.2.1,6.3,6.3.1,6.3.2,6.3.3,7.3.1,7.3.2.1,7.3.2.2,7.3.2.2.1,7.3.2.2.2,  
7.3.2.2.3,7.3.3,7.7.5,6.2.7,7.2.1,7.7.2.2,7.7.4,7.7.4.1,7.7.7.4.2,7.9.2.1,7.9.7,7.9.8,6.5.1,7.9.9,  
7.9.3,7.9.3.1,7.9.3.2,7.9.5.1,7.9.4,6.2.12,6.2.13.

**The validity of the certificate is limited to:** 30.6.2012

18.6.2009

Prague

Miroslav Sedláček  
Certification and Inspection Manager



902126-01