

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRUFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1100835

Product: Fuse-links for the protection of semiconductors devices

Type: P5...06 gR,aR

Rating: 690 V AC, 400 V DC, 6-630 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 003188-01/01 of: 19.11.2010

A sample of the product was found to be in conformity with:
ČSN EN 60269-1ed. 3:08+A1:10, ČSN EN 60269-4 ed. 3:10, ČSN EN 60269-4 ed.2:08+Z1:10

The validity of the certificate is limited to: 30.11.2013

25.11.2010

Prague

Miroslav Sedláček
Certification and Inspection Manager



Stamp



* C E R / 1 1 0 0 8 3 5 *

003188-01