

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140346

Product: Circuit breaker MINIA

Type: LPN

Rating: 0,2; 0,4; 0,6; 0,8; 1; 1,2; 1,6; 2; 4; 6; 8; 10; 13; 16; 20; 25; 32; 40; 50; 63 A (1p);
0,2; 0,5; 0,6; 0,8; 1; 1,2; 1,6; 2; 4; 6; 8; 10; 13; 16; 20; 25; 32; 40; 50; 63 A (3p);
AC 230/400 V, char.: B, C, D, 10 kA

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 401656-01/01 of: 23.04.2014

A sample of the product was found to be in conformity with:
ČSN EN 60898-1:03+A1:05+1:05+A11:06+A12:08+A13:13

The validity of the certificate is limited to: 30.4.2017

24.4.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



401656-01