

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140402

Product: Shunt trip

Type: SV-LP-X060, SV-LP-X400 AC/DC

Rating: SV-LP-X060 = 12-60 V AC/DC; SV-LP-X400 = 110-415 V AC, 100-220 V DC

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 401661-01/01 of: 05.05.2014

A sample of the product was found to be in conformity with:

ČSN EN 60947-1 ed.4:08+A1:11 cl.5, 5.1, 5.2, 7.1.8.4, 7.2.3.1, 7.1.3, 5.2.1, 7.2.4.1a), 7.1.4; ČSN EN 60947-5-1 ed.2:05+1:05+A1:10 cl.7.2.4.3, 7.2.4.1a), 7.1.3; ČSN EN 60898-1:03+A1:05+1:05+A11:06+A12:08+A13:13 cl.9.3, 9.4, 9.14.1, 9.13.2, 9.14.2, 9.15

The validity of the certificate is limited to: 31.5.2017

19.5.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



401661-01