

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1150072

**Product:** Disconnecter

**Type:** APN

**Rating:** AC 230/400 V, 32 A, 63 A

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 500287-01/01 of: 30.01.2015

**A sample of the product was found to be in conformity with:**  
ČSN EN 60947-3 ed.3:10+A1:12, ČSN EN 60947-1 ed.4:08+A1:11

**The validity of the certificate is limited to:** 28.2.2018

4.2.2015

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



500287-01