

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1170090

Product: Fuse-links for the protection of semiconductors devices

Type: P5...06 gR, aR

Rating: 690 V AC, 400 V DC, 6-630 A

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 700286-01/01 of: 31.01.2017

A sample of the product was found to be in conformity with:
ČSN EN 60269-1ed.3:08+A1:10+A2:15 cl. 8.8, 8.1.5.1, 8.4.3.3, 8.4.3.6, 8.5.5.2, 8.6, 8.7, 8.8,
ČSN EN 60269-4 ed.3:10+A1:13 cl. 8.3, 8.4.3.1, 8.4.3.2, 8.4.3.4, 8.5

Other data:

The validity of the certificate is limited to: 28.02.2020

08.02.2017

Prague


Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



700286-01