

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1070024

Product: Residual current operated circuit-breakers

Type: OFE 20, 40

Rating: 230/400 V; 25, 40, 63 A; 50/60 Hz, Inc = 6 kA, I_{res} = 0,03 A; 0,3 A

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 604552-01/01 of: 20.12.2006

A sample of the product was found to be in conformity with:
EN 61008-1:04 ed.2, EN 61008-2-1:94,
ČSN EN 61008-1:05 ed.2, ČSN EN 61008-2-1:97+A11:99

The validity of the certificate is limited to: 31.1.2010

10.1.2007

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



604552-01