

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1070715

**Product:** Two-pole socket-outlet with earthing contacts (for contact strips)

**Type:** ZS20.

**Rating:** 16 A, AC 250 V

**Ordering firm:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s.r.o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

The test results are stated in the test-report No.: 702732-01/01 of: 29.08.2007

A sample of the product was found to be in conformity with:  
ČSN IEC 60 884-1:03+1:04, ČSN 354516:07

The validity of the certificate is limited to: 30.9.2010

7.9.2007

Prague

Pavel Kudrna  
Certification and Inspection Manager



Stamp



702732-01