

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1070716

Product: Double push-button switch

Type: M2T, MT2B

Rating: Ith=25 A, Ue AC 230/400 V, DC 220 V, AC 12-25 A, AC 15-6 A, DC 12-1 A

Ordering firm: O EZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: O EZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 702733-01/01 of: 29.08.2007

A sample of the product was found to be in conformity with:
ČSN EN 60947-5-1:05 ed.2, ČSN EN 60947-1:05 ed. 3

The validity of the certificate is limited to: 30.9.2010

7.9.2007

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



702733-01