

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1070718

Product: LST Circuit breaker

Type: LST

Rating: Un=230/400 V AC, In=40, 50, 63, 80, 100, 125 A, char. B, C, D, 1p, 3p, 3p+N

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 702735-01/01 of: 30.08.2007

A sample of the product was found to be in conformity with:
ČSN EN 60898-1:03+A1:05+1:05

The validity of the certificate is limited to: 30.9.2010

7.9.2007

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



* C E R / 1 0 7 0 7 1 8 *

702735-01