

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRUFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - REPUBLIQUE TCHEQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1110760

Product: Plastic box for switchboard

Type: CT-3G, CT-4G

Rating: 400 V, max 63 A, IP 55

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 101757-01/01 of: 19.08.2011

A sample of the product was found to be in conformity with:
ČSN EN 62208:2004; ČSN EN 62262:97+A1:99+1:2004

The validity of the certificate is limited to: 31.8.2014

25.8.2011

Prague

Jarmil Mikulík
Deputy Head of Certification Body



Stamp



101757-01