

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1140401

**Product:** Auxiliary and relative switch

**Type:** PS-LP-110S, PS-LP-200S, PS-LP-020S, PS-LP-001S

**Rating:** AC-12 230 V AC / 6 A; AC-13 230 V AC / 4 A or 400 V AC / 2 A; AC-15 230 V AC / 3 A;  
DC-13 220 V DC / 0,55 A; Uimp.-4 kV

**Ordering firm:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Manufacturer:** OEZ s. r. o.  
Šedivská 339, 561 51 Letohrad, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 401660-01/01 of: 07.05.2014

**A sample of the product was found to be in conformity with:**

ČSN EN 60947-5-1:05 ed.2+1:05+A1:10, ČSN EN 60947-1 ed.4:08+A1:11 cl.5, 5.1, 8.3.3.3, 8.3.3.4, 8.2.4, 8.3.3.5.2, 8.3.3.5.5b, 8.3.3.5.3, 8.3.4, 8.2.5, 8.2.6, 7.1.3; ČSN EN 60898-1:03+A1:05+1:05+A11:06+A12:08+A13:13 cl.9.3, 9.4, 9.14, 9.14.1, 9.15

**The validity of the certificate is limited to:** 31.5.2017

19.5.2014

Prague

Miroslav Sedláček  
Head of Certification Body



Stamp



401660-01