

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140403

Product: Strip fuse way switch

Type: FD1-31, FD1-33, FD2-31, FD2-33, FD3-31, FD3-33

Rating: 250 A, 400 A, 630 A, AC 690 V 22B, 400 V 23B

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 401663-01/01 of: 06.05.2014

A sample of the product was found to be in conformity with:
ČSN EN 60947-3 ed.3:10+A1:12

The validity of the certificate is limited to: 31.5.2017

19.5.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



401663-01