

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140404

Product: Undervoltage releases MINIA

Type: SP-LP-.. see enclosure

Rating: 24-400 V AC/DC

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 401659-01/01 of: 13.05.2014

A sample of the product was found to be in conformity with:
ČSN EN 60947-1:08 ed.4+A1:11 cl.5,5.1,7.1.8.4,7.1.4,7.2.1.3,7.2.2.6,8.2.1.1.1,
ČSN EN 60898-1:03+A1:05+1:05+A11:06+A12:08+A13:13 cl.9.3,9.4,9.7.4,9.7.5,9.7.6,2,9.3,9.11,9.13,2,9.14.1,9.14.2,9.15,

The validity of the certificate is limited to: 31.5.2017

19.5.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



401659-01

Type designation of SP-LP undervoltage release

SP-LP-A024	24 V AC	
SP-LP-A048	48 V AC	
SP-LP-A110	110 V AC	
SP-LP-A230	230 V AC	
SP-LP-A230-T004	230 V AC	delay 0,4 s
SP-LP-A400	400 V AC	
SP-LP-D024-Y004	24 V DC	delay 0 s or 0,2 s
SP-LP-D048-Y004	48 V DC	delay 0 s or 0,2 s
SP-LP-D110-Y004	110 V DC	delay 0 s or 0,2 s
SP-LP-D220-Y004	220 V DC	delay 0 s or 0,2 s
SP-LP-D400-Y004	400 V DC	delay 0 s or 0,2 s

