

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140417

Product: Fuse-rail

Type: series FR.-.... size 00, 1, 2 and 3

Rating: 160 A, 250 A, 400 A, 630 A, 690 V AC

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 401662-01/01 of: 19.05.2014

A sample of the product was found to be in conformity with:
ČSN EN 60269-1 ed.3:08+A1:10 čl. 8.1.4, 8.2, 8.3, 8.11.2.2, 8.11.2.3,
ČSN 35 4701-2 ed.2:11

The validity of the certificate is limited to: 31.5.2017

26.5.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



401662-01