

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140709

Product: Fuse switch-disconnectors- vertical design

Type: FD00-33K/F, FD00-3.D/F.

Rating: 690 V AC, 160 A, IP 30

Ordering firm: O EZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: O EZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 103461-01/01 of: 23.08.2011

A sample of the product was found to be in conformity with:
ČSN EN 60947-1 ed.4:08, ČSN EN 60947-3 ed.3:10

The validity of the certificate is limited to: 31.8.2015

13.8.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



403392-01